Name of Facility	
------------------	--

Date of Survey Pro	vider#	
--------------------	--------	--

		EMERGENCY PREPAREDNESS REQUIREMENTS				LONG TERM CARE FACILITIES
Tag #	Title	Tag Text (Regulatory Text)	MET	NOT MET	N/A	REMARKS
E0001	Establishment of the Emergency Program (EP)	The facility must comply with all applicable Federal, State and local emergency preparedness requirements. The [facility] must establish and maintain a comprehensive emergency preparedness program that meets the requirements of this section.*				CFR 483.73
E0004	Develop and Maintain EP Program	[The [facility] must comply with all applicable Federal, State and local emergency preparedness requirements. The [facility] must develop establish and maintain a comprehensive emergency preparedness program that meets the requirements of this section.] The emergency preparedness program must include, but not be limited to, the following elements:] (a) Emergency Plan. The [facility] must develop and maintain an emergency				CFR 483.73(a)
		preparedness plan that must be [reviewed], and updated at least annually.				
E0006	Maintain and Annual EP Updates	((a) Emergency Plan. The [facility] must develop and maintain an emergency preparedness plan that must be reviewed, and updated at least annually. The plan must do the following:]				CFR 483.73(a)(1)-(2)
		(1) Be based on and include a documented, facility-based and community-based risk assessment, utilizing an all-hazards approach.* *[For LTC facilities at §483.73(a)(1):] (1) Be based on and include a documented, facility-based and community-based risk assessment, utilizing an all-hazards approach, including missing residents.				
		*[For ICF/IIDs at §483.475(a)(1):] (1) Be based on and include a documented, facility-based and community-based risk assessment, utilizing an all-hazards approach, including missing clients.				
		(2) Include strategies for addressing emergency events identified by the risk assessment.				
E0007	EP Program Patient Population	[(a) Emergency Plan. The [facility] must develop and maintain an emergency preparedness plan that must be reviewed, and updated at least annually. The plan must do the following:]				CFR 483.73(a)(3)
		(3) Address patient/client population, including, but not limited to, persons at-risk; the type of services the [facility] has the ability to provide in an emergency; and continuity of operations, including delegations of authority and succession plans.**				
E0009	Process for EP Collaboration	((a) Emergency Plan. The [facility] must develop and maintain an emergency preparedness plan that must be reviewed, and updated at least annually. The plan must do the following:]				CFR 483.73(a)(4)
		(4) Include a process for cooperation and collaboration with local, tribal, regional, State, and Federal emergency preparedness officials' efforts to maintain an integrated response during a disaster or emergency situation, including documentation of the facility's efforts to contact such officials and, when applicable, of its participation in collaborative and cooperative planning efforts. **				

		EMERGENCY PREPAREDNESS REQUIREMENTS				LONG TERM CARE FACILITIES
Tag #	Title	Tag Text (Regulatory Text)	MET	NOT MET	N/A	REMARKS
E0013	Development of EP Policies and Procedures	(b) Policies and procedures. [Facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.				CFR 483.73(b)
E0015	Subsistence needs for staff and patients	[(b) Policies and procedures. [Facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.] At a minimum, the policies and procedures must address the following: (1) The provision of subsistence needs for staff and patients whether they evacuate or shelter in place, include, but are not limited to the following: (i) Food, water, medical and pharmaceutical supplies (ii) Alternate sources of energy to maintain the following: (A) Temperatures to protect patient health and safety and for the safe and sanitary storage of provisions. (B) Emergency lighting. (C) Fire detection, extinguishing, and alarm systems. (D) Sewage and waste disposal.				CFR 483.73(b)(1)
E0018	Procedures for Tracking of Staff and Patients	[(b) Policies and procedures. The [facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.] At a minimum, the policies and procedures must address the following:] (2) A system to track the location of on-duty staff and sheltered patients in the [facility's] care during an emergency. If on-duty staff and sheltered patients are relocated during the emergency, the [facility] must document the specific name and location of the receiving facility or other location. *[For LTC at §483.73(b), ICF/IIDs at §483.475(b):] Policies and procedures. (2) A system to track the location of on-duty staff and sheltered residents in the [LTC or ICF/IID] care during and after an emergency. If on-duty staff and sheltered residents are relocated during the emergency, the [LTC or ICF/IID] must document the specific name and location of the receiving facility or other location.				CFR 483.73(b)(2)
E0020	Policies and Procedures including Evacuation	[(b) Policies and procedures. The [facilitles] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually. At a minimum, the policies and procedures must address the following:] Safe evacuation from the [facility], which includes consideration of care and treatment needs of evacuees; staff responsibilities; transportation; identification of evacuation location(s); and primary and alternate means of communication with external sources of assistance.				CFR 483.73(b)(3)

		EMERGENCY PREPAREDNESS REQUIREMENTS				LONG TERM CARE FACILITIES
Гад #	Title	Tag Text (Regulatory Text)	MET	NOT MET	N/A	REMARKS
E0022	Policies and Procedures for Sheltering	(b) Policies and procedures. The [facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.] At a minimum, the policies and procedures must address the following:] (4) A means to shelter in place for patients, staff, and volunteers who remain in the [facility].				CFR 483.73(b)(4)
E0023	Policies and Procedures for Medical Docs.	[(b) Policies and procedures. The [facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.] At a minimum, the policies and procedures must address the following:] (5) A system of medical documentation that preserves patient information, protects confidentiality of patient information, and secures and maintains availability of records.				CFR 483.73(b)(5)
E0024	for Volunteers	emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.] At a minimum, the policies and procedures must address the following:] (6) [or (4), (5), or (7) as noted above] The use of volunteers in an emergency or other emergency staffing strategies, including the process and role for integration of State and Federally designated health care professionals to address surge needs during an emergency.				CFR 483.73(b)(6)
E0025		[(b) Policies and procedures. The [facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.] At a minimum, the policies and procedures must address the following: *[For LTC Facilities at §483.73(b):] Policies and procedures. (7) [or (5)] The development of arrangements with other [facilities] [and] other providers to receive patients in the event of limitations or cessation of operations to maintain the continuity of services to facility patients.	-			CFR 483.73(b)(7)

		EMERGENCY PREPAREDNESS REQUIREMENTS			,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	LONG TERM CARE FACILITIES
Tag #	Title	Tag Text (Regulatory Text)	MET	NOT MET	N/A	ŘÉMARKS
E0026	Roles under a Walver Declared by Secretary	[(b) Policies and procedures. The [facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.] At a minimum, the policies and procedures must address the following:] (B) [(6), (6)(C)(iv), (7), or (9)] The role of the [facility] under a waiver declared by the Secretary, in accordance with section 1135 of the Act, in the provision of care and treatment at an alternate care site identified by emergency management officials.				CFR 483.73(b)(8)
E0029	Development of Communication Plan	(c) The [facility] must develop and maintain an emergency preparedness communication plan that complies with Federal, State and local laws and must be reviewed and updated at least annually.				CFR 483.73(c)
E0030	Names and Contact Information	[(c) The facility must develop and maintain an emergency preparedness communication plan that complies with Federal; State and local laws and must be reviewed and updated at least annually.] The communication plan must include all of the following: (1) Names and contact information for the following: (i) Staff. (ii) Entities providing services under arrangement. (iii) Patients' physicians (Iv) Other [facilities]. (v) Volunteers.				CFR 483.73(c)(1)
E0031	Emergency Officials Contact Information	[(c) The facility must develop and maintain an emergency preparedness communication plan that complies with Federal, State and local laws and must be reviewed and updated at least annually] The communication plan must include all of the following: (2) Contact information for the following: (i) Federal, State, tribal, regional, and local emergency preparedness staff. (ii) Other sources of assistance. *[For LTC Facilities at §483.73(c):] (2) Contact information for the following: (i) Federal, State, tribal, regional, or local emergency preparedness staff. (ii) The State Licensing and Certification Agency. (iii) The Office of the State Long-Term Care Ombudsman. (iv) Other sources of assistance. *[For ICF/IIDs at §483.475(c):] (2) Contact information for the following: (i) Federal, State, tribal, regional, and local emergency preparedness staff. (ii) Other sources of assistance.				CFR 483.73(e)(2)

		EMERGENCY PREPAREDNESS REQUIREMENTS				LONG TERM CARE FACILITIES
Tag #	Title	Tag Text (Regulatory Text)	MET	NOT MET	N/A	REMARKS
E0032	Primary/Alternate Means for Communication	[(c) The [facility] must develop and maintain an emergency preparedness communication plan that complies with Federal, State and local laws and must be reviewed and updated at least annually.] The communication plan must include all of the following: (3) Primary and alternate means for communicating with the following: (i) [Facility] staff. (ii) Federal, State, tribal, regional, and local emergency management agencies. *[For ICF/IIDs at §483.475(c):] (3) Primary and alternate means for communicating with the ICF/IID's staff, Federal, State, tribal, regional, and local emergency management agencies.				CFR 483.73(c)(3)
E0033	Methods for Sharing Information	[(c) The [facility] must develop and maintain an emergency preparedness communication plan that complies with Federal, State and local laws and must be reviewed and updated at least annually.] The communication plan must include all of the following: (4) A method for sharing information and medical documentation for patients under the [facility's] care, as necessary, with other health providers to maintain the continuity of care. (5) A means, in the event of an evacuation, to release patient information as permitted under 45 CFR 164.510(b)(1)(ii). (6) [(4) or (5)]A means of providing information about the general condition and location of patients under the [facility's] care as permitted under 45 CFR 164.510(b)(4).				CFR 483.73(c)(4)-(6)
E0034	Sharing Information on Occupancy/Needs	[(c) The [facility] must develop and maintain an emergency preparedness communication plan that complies with Federal, State and local laws and must be reviewed and updated at least annually.] The communication plan must include all of the following: (7) [(5) or (6)] A means of providing information about the [facility's] occupancy, needs, and its ability to provide assistance, to the authority having jurisdiction, the Incident Command Center, or designee.				CFR 483.73(c)(7)
E0035	LTC and ICF/IID Family Notifications	[(c) The [LTC facility and ICF/IID] must develop and maintain an emergency preparedness communication plan that complies with Federal, State and local laws and must be reviewed and updated at least annually.] The communication plan must include all of the following: (8) A method for sharing information from the emergency plan, that the facility has determined is appropriate, with residents [or clients] and their families or representatives.				CFR 483.73(c)(8)

		EMERGENCY PREPAREDNESS REQUIREMENTS				LONG TERM CARE FACILITIES
Tag #	Title	Tag Text (Regulatory Text)	MÉT	NOT MET	N/A	REMARKS
E0036	Emergency Prep Training and Testing	(d) Training and testing. The [facility] must develop and maintain an emergency preparedness training and testing program that is based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, policies and procedures at paragraph (b) of this section, and the communication plan at paragraph (c) of this section. The training and testing program must be reviewed and updated at least annually. *[For ICF/IIDs at §483.475(d):] Training and testing. The ICF/IID must develop and maintain an emergency preparedness training and testing program that is based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, policies and procedures at paragraph (b) of this section, and the communication plan at paragraph (c) of this section. The training and testing program must be reviewed and updated at least annually. The ICF/IID must meet the requirements for evacuation drills and training at §483.470(h).				CFR 483.73(d)
E0037	Emergency Prep Training Program	(1) Training program. The facility must do all of the following: (i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected role. (ii) Provide emergency preparedness training at least annually. (iii) Maintain documentation of the training. (iv) Demonstrate staff knowledge of emergency procedures.				CFR 483.73(d)(1)
E0039	Emergency Prep Testing Requirements	(2) Testing. *[For LTC Facilities at §483.73(d):] (2) Testing. The LTC facility must conduct exercises to test the emergency plan at least annually, including unannounced staff drills using the emergency procedures. The LTC facility must do all of the following:] (i) Participate in a full-scale exercise that is community-based or when a community-based exercise is not accessible, an individual, facility-based. If the [facility] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in a community-based or individual, facility-based full-scale exercise for 1 year following the onset of the actual event. (Ii) Conduct an additional exercise that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or individual, facility-based. (B) A tabletop exercise that includes a group discussion led by a facilitator, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [facility's] emergency plan, as needed.				CFR 483.73(d)(2)

		EMERGENCY PREPAREDNESS REQUIREMENTS				LONG TERM CARE FACILITIES
Tag #	Title	Tag Text (Regulatory Text)	MET	NOT MET	N/A	REMARKS
E0041		\$483.73(e), §485.625(e) (e) Emergency and standby power systems. The [LTC facility] must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section. §482.15(e)(1), §483.73(e)(1), §485.625(e)(1) Emergency generator location. The generator must be located in accordance with the location requirements found in the Health Care Facilities Code (NFPA 99 and Tentative Interim Amendments TIA 12–2, TIA 12–3, TIA 12–4, TIA 12–5, and TIA 12–6), Life Safety Code (NFPA 101 and Tentative Interim Amendments TIA 12–1, TIA 12–2, TIA 12–3, and TIA 12–4), and NFPA 110, when a new structure is built or when an existing structure or building is renovated. 482.15(e)(2), §483.73(e)(2), §485.625(e)(2) Emergency generator inspection and testing. The [LTC facility] must implement the emergency power system inspection, testing, and maintenance requirements found in the Health Care Facilities Code, NFPA 110, and Life Safety Code. 482.15(e)(3), §483.73(e)(3), §485.625(e)(3) Emergency generator fuel. [LTC facility] that maintain an onsite fuel source to power emergency generators must have a plan for how it will keep emergency power systems operational during the emergency, unless it evacuates.				CFR 483.73(e)
		"[For LTC at §483.73(g):] The standards incorporated by reference in this section are approved for incorporation by reference by the Director of the Office of the Federal Register in accordance with 5 U.S.C, 552(a) and 1 CFR part 51. You may obtain the material from the sources listed below. You may inspect a copy at the CMS Information Resource Center, 7500 Security Boulevard, Baltimore, MD or at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202–741–6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations. html. If any changes in this edition of the Code are incorporated by reference, CMS will publish a document in the Federal Register to announce the changes. (1) National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169, www.nfpa.org, 1.617.770.3000. (1) NFPA 99, Health Care Facilities Code, 2012 edition, issued August 11, 2011. (iii) TiA 12–3 to NFPA 99, issued August 9, 2012. (iv) TIA 12–4 to NFPA 99, issued August 1, 2013. (vi) TIA 12–6 to NFPA 99, issued March 7, 2013. (vi) TIA 12–6 to NFPA 99, issued March 3, 2014. (vii) NFPA 101, Life Safety Code, 2012 edition, issued August 11, 2011. (viii) TIA 12–2 to NFPA 101, issued August 11, 2011. (viii) TIA 12–3 to NFPA 101, issued August 11, 2011. (viii) TIA 12–3 to NFPA 101, issued October 30, 2012. (x) TIA 12–3 to NFPA 101, issued October 22, 2013. (xi) TIA 12–4 to NFPA 101, issued October 22, 2013. (xii) NFPA 110, Standard for Emergency and Standby Power Systems, 2010 edition, including TIAs to chapter 7, issued August 6, 2009.				